

Stoughton High School  
 232 Pearl Street  
 Stoughton, Ma 02072

19 samples, 1st Draw  
 (Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comments
1st	505-01	Kitchen Pot Washing Sink	1/2/2012	0617	0.00222	Sign
1st	505-02	Teach Dining Rm Sink	1/2/2012	0619	0.0107	Sign
1st	505-03	Café Fountain	1/2/2012	0621	0.00141	
1st	505-07	Boys PE LR Fountain	1/2/2012	0625	0.00271	Sign
1st	505-09	Fountain Adj to Rm D101	1/2/2012	0627	0.00266	
1st	505-14	Fountain Opp Rock Rm	1/2/2012	0629	0.0141	
1st	505-15	Fountain Opp Business Ofc	1/2/2012	0630	0.00299	
1st	505-18	Business Ofc Sink	1/2/2012	0632	0.00305	
2nd	505-21	Supers Ofc Kitchen Sink	1/2/2012	0635	0.00449	
2nd	505-25	Sink in Rm B201	1/2/2012	0640	0.00163	
2nd	505-29	Fountain Opp B201	1/2/2012	0642	0.00343	
2nd	505-33	Clinic Lav (L)	1/2/2012	0645	0.0138	Sign
2nd	505-34	Clinic Lav (C)	1/2/2012	0646	0.0111	Sign
2nd	505-35	Clinic Lav (R)	1/2/2012	0647	0.00227	Sign
2nd	505-36	Fountain in Big Gym	1/2/2012	0650	0.00357	
2nd	505-37	Fountain in Big Gym	1/2/2012	0651	0.00271	
2nd	505-41	Fountain Adj to Rm D207	1/2/2012	0653	0.00358	
3rd	505-45	Fountain Opp Rm B309	1/2/2012	0655	0.00753	
3rd	505-46	Fountain Opp Rm B301	1/2/2012	0657	0.0056	

Robert G. O'Donnell Middle School  
 211 Cushing Street  
 Stoughton, Ma 02072

13 samples, 1st Draw  
 (Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comments
1st	405-01	Kitchen Pot Washing Sink	1/2/2012	0712	0.00133	Sign
1st	405-02	Teachers Rm Sink	1/2/2012	0714	0.00225	Sign
1st	405-03	Clinic Lav (L)	1/2/2012	0716	0.00604	Sign
1st	405-04	Clinic Lav (R)	1/2/2012	0717	0.00894	Sign
1st	405-11	Fountain Adj to Rm #107	1/2/2012	0720	0.00223	
1st	405-12	Fountain Adj to Rm #120	1/2/2012	0722	0.00119	
1st	405-15	Fountain Opp Media Ctr	1/2/2012	0724	ND	
1st	405-19	Fountain in Gym (L)	1/2/2012	0725	ND	
1st	405-20	Fountain in Gym (R)	1/2/2012	0726	ND	
2nd	405-22	Fountain Adj to Rm #207	1/2/2012	0730	ND	
2nd	405-26	Fountain Adj to Rm #221	1/2/2012	0733	0.00372	
MOD	405-32	Fountain Adj to Boys Rm (U)	1/2/2012	0737	0.00101	
MOD	405-33	Fountain Adj to Boys Rm (L)	1/2/2012	0738	0.00120	

E.A. Jones Elementary School  
137 Walnut Street  
Stoughton, Ma 02072

4 samples, 1st Draw

(Action Limit: 0.015 mg/L)

Floor	I.D #.	Location	Date:	Time:	Results: (mg/L)	Comment
1st	012-03	Fountain Opp Library	1/2/2012	0945	0.00135	
1st	012-05	Sink; Teachers Café	1/2/2012	0949	0.00174	Sign
2nd	012-09	Clinic Lav	1/2/2012	0952	0.00203	Sign
2nd	012-10	Fountain Adj to Rm 11	1/2/2012	0955	0.00768	

Helen H. Hansen Elementary School  
 1800 Central St  
 Stoughton, Ma 02072

10 samples, 1st Draw  
 (Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comment:
1st	010-03	Teachers Cafe Sink	1/2/2012	0820	0.00122	Sign
1st	010-04	Fountain Opp Rm #18 (U)	1/2/2012	0822	ND	
1st	010-05	Clinic R/R Lav	1/2/2012	0825	0.00417	Sign
1st	010-06	Fountain Opp Rm #5 (U)	1/2/2012	0827	ND	
1st	010-09	Kitchen Pot Sink	1/2/2012	0829	0.00153	Sign
1st	010-12	Fountain outside Gym (U)	1/2/2012	0831	0.00103	
1st	010-13	Fountain outside Gym (L)	1/2/2012	0832	ND	
1st	010-14	Fountain Opp Rm #18 (L)	1/2/2012	0833	0.00102	
1st	010-15	Fountain Opp Rm #5 (L)	1/2/2012	0834	ND	
1st	010-16	HP R/R Lav	1/2/2012	0835	0.00136	

South Elementary School  
131 Ash Street  
Stoughton, Ma 02072

7 samples, 1st Draw

(Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comments
1st	015-03	Fountain Opp Rm #10	1/2/2012	0925	0.00384	(New)
1st	015-06	Fountain Opp Rm #5	1/2/2012	0927	0.00311	(New)
1st	015-07	Clinic Lav	1/2/2012	0929	0.0154	Sign (New)
1st	015-08	Fountain Opp Café	1/2/2012	0931	0.00464	(New)
1st	015-10	Teacher Café Sink	1/2/2012	0932	0.0330	Sign
1st	015-12	Kitchen Pot Washing Sink	1/2/2012	0934	0.0280	Sign
1st	015-13	Fountain Adj to Gym	1/2/2012	0935	0.00392	(New)

West Elementary School  
 1322 Central Street  
 Stoughton, Ma 02072

11 samples, 1st Draw  
 (Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comments
1st	020-03	Fountain Adj to Elevator	01/02/12	0740	ND	Plastic Pipe
1st	020-04	Fountain Opp Gym	01/02/12	0742	ND	Plastic Pipe
1st	020-05	Kitchen Pot Washing Sink	01/02/12	0744	ND	Sign
1st	020-06	Fountain in Café	01/02/12	0746	ND	Plastic Pipe
1st	020-07	Fountain Adj to Rm #4	01/02/12	0748	ND	Plastic Pipe
2nd	020-10	Fountain Adj Rm #12	01/02/12	0750	0.00136	Plastic Pipe
2nd	020-11	Fountain Adj Rm #14	01/02/12	0752	ND	Plastic Pipe
2nd	020-12	Fountain Adj Rm #10	01/02/12	0754	ND	Plastic Pipe
2nd	020-13	Fountain Adj Rm #23	01/02/12	0756	0.00348	Plastic Pipe
2nd	020-14	Clinic Lav	01/02/12	0758	0.00113	Sign
2nd	020-15	Teachers 2nd RR Lav	01/02/12	0800	0.00348	Sign

Joseph R. Dawe Elementary School  
 131 Pine Street  
 Stoughton, Ma 02072

10 samples, 1st Draw

(Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comment
1st	014-01	Fountain Opp Elev	1/2/12	0957	0.00276	Plastic Pipe
1st	014-02	Fountain Opp Rm A (U)	1/2/12	0959	0.00321	Plastic Pipe
1st	014-03	Fountain Opp Rm A (L)	1/2/12	1001	ND	Plastic Pipe
1st	014-04	Clinic Lav	1/2/12	1003	0.00361	Sign
1st	014-06	Kitchen Pot Washing Sink	1/2/12	1006	0.00835	Sign
1st	014-10	Fountain behind Café	1/2/12	1008	0.00283	Plastic Pipe
1st	014-13	Fountain Opp Rm #11	1/2/12	1010	0.00809	Plastic Pipe
2nd	014-20	Fountain Adj to Girls Rm	1/2/12	1011	0.00221	Plastic Pipe
2nd	014-21	Fountain Adj to Boys Rm	1/2/12	1013	0.0019	Plastic Pipe
1st	014-22	Teachers Cafe Sink	1/2/12	1015	0.00887	Sign

Joseph H. Gibbons Elementary School  
 235 Morton Street  
 Stoughton, Ma 02072

10 samples, 1st Draw

(Action Limit: 0.015 mg/L)

Floor	I.D #:	Location	Date:	Time:	Results: (mg/L)	Comment
1st	025-01	Fountain Adj to Ofc (U)	1/2/2012	0845	0.00216	Plastic Pipe
1st	025-02	Fountain Adj to Ofc (L)	1/2/2012	0846	ND	Plastic Pipe
1st	025-04	Clinic Sink	1/2/2012	0848	0.0116	Sign
1st	025-08	Teachers Cafe Sink	1/2/2012	0850	0.00985	Sign
1st	025-09	Kitchen Pot Washing Sink	1/2/2012	0852	0.00331	Sign
1st	025-10	Fountain Behind Café	1/2/2012	0854	0.00198	Plastic Pipe
1st	025-13	Fountain Opp Rm #7	1/2/2012	0857	0.00191	Plastic Pipe
1st	025-15	Fountain Opp Elev	1/2/2012	0900	0.00196	Plastic Pipe/Flush
2nd	025-19	Fountain Adj to Rm #35	1/2/2012	0903	0.00202	Plastic Pipe
2nd	025-20	Fountain Adj to Store Rm	1/2/2012	0905	0.00236	Plastic Pipe

Stoughton Public Library  
84 Park St  
Stoughton, Ma 02072

3 samples, 1st Draw  
(Action Limit: 0.015 mg/L)

Floor	I.D #:	Type:	Location	Date:	Time:	Results: (mg/L)
1st	84-01	F	Childrens Area	1/4/2012	0830	0.00216
2nd	84-02	S	Staff Dining Rm	1/4/2012	0831	0.00298
2nd	84-03	S	Wales French Kitchen	1/4/2012	0833	0.00204