

Stoughton High School
232 Pearl Street
Stoughton, Ma 02072

1 sample, 1st Draw

(Action Limits: 0.015 mg/L - Lead, 1.3 mg/L - Copper)

| Floor | I.D #: | Location | Date: | Time: | Lead: (mg/L) | Copper: (mg/L) | Comments |
|-------|--------|----------------------|----------|-------|-----------------|-------------------|----------|
| 1st | 505-02 | Teach Dining Rm Sink | 2/7/2018 | 6:14 | 0.022 | 0.471 | |

Robert G. O'Donnell Middle School
211 Cushing Street
Stoughton, Ma 02072

5 samples, 1st Draw

(Action Limits: 0.015 mg/L - Lead, 1.3 mg/L - Copper)

| Floor | I.D #: | Location | Date: | Time: | Lead: (mg/L) | Copper: (mg/L) | Comments |
|-------|--------|-----------------------------|----------|-------|-----------------|-------------------|----------|
| 1st | 405-12 | Fountain Adj to Rm #120 | 2/7/2018 | 6:27 | 0.003 | 3.150 | Flush |
| 2nd | 405-22 | Fountain Adj to Rm #207 | 2/7/2018 | 6:30 | 0.004 | 1.610 | Flush |
| 2nd | 405-26 | Fountain Adj to Rm #221 | 2/7/2018 | 6:31 | 0.006 | 1.360 | Flush |
| MOD | 405-32 | Fountain Adj to Boys Rm (U) | 2/7/2018 | 6:33 | 0.002 | 1.330 | Flush |
| MOD | 405-33 | Fountain Adj to Boys Rm (L) | 2/7/2018 | 6:34 | 0.002 | 1.490 | Flush |

E.A. Jones Elementary School
137 Walnut Street
Stoughton, Ma 02072

1 sample, 1st Draw

(Action Limits: 0.015 mg/L - Lead, 1.3 mg/L - Copper)

| Floor | I.D #: | Location | Date: | Time: | Lead: (mg/L) | Copper: (mg/L) | Comment |
|-------|--------|-----------------------|----------|-------|-----------------|-------------------|---------|
| 2nd | 012-10 | Fountain Adj to Rm 11 | 2/7/2018 | 7:06 | 0.005 | 1.460 | Flush |

South Elementary School
131 Ash Street
Stoughton, Ma 02072

3 samples, 1st Draw

(Action Limits: 0.015 mg/L - Lead, 1.3 mg/L - Copper)

| Floor | I.D #: | Location | Date: | Time: | Lead: (mg/L) | Copper: (mg/L) | Comments |
|-------|--------|---------------------|----------|-------|-----------------|-------------------|--------------------|
| 1st | 015-03 | Fountain Opp Rm #10 | 2/7/2018 | 6:57 | 0.0134 | 0.373 | Automatic Flush |
| 1st | 015-07 | Clinic Lav | 2/7/2018 | 6:59 | 0.0055 | 0.426 | |
| 1st | 015-10 | Teacher Café Sink | 2/7/2018 | 7:02 | 0.0006 | 0.112 | |

West Elementary School
1322 Central Street
Stoughton, Ma 02072

1 samples, 1st Draw

(Action Limits: 0.015 mg/L - Lead, 1.3 mg/L - Copper)

| Floor | I.D #: | Location | Date: | Time: | Lead: (mg/L) | Copper: (mg/L) | Comments |
|-------|--------|------------------|----------|-------|-----------------|-------------------|----------|
| 1st | 020-06 | Fountain in Café | 2/7/2015 | 6:40 | 0.002 | 4.110 | Replaced |

Joseph R. Dawe Elementary School
131 Pine Street
Stoughton, Ma 02072

5 samples, 1st Draw

(Action Limits: 0.015 mg/L - Lead, 1.3 mg/L Copper)

| Floor | I.D #: | Location | Date: | Time: | Lead: (mg/L) | Copper: (mg/L) | Comment |
|-------|--------|--------------------------|--------|-------|-----------------|-------------------|----------------------|
| 1st | 014-02 | Fountain Opp Rm A (U) | 2/7/18 | 7:18 | 0.064 | 0.889 | Removed From Service |
| 1st | 014-03 | Fountain Opp Rm A (L) | 2/7/18 | 7:19 | 0.039 | 0.617 | Removed from Service |
| 1st | 014-08 | Kitchen Pot Washing Sink | 2/7/18 | 7:22 | 0.014 | 2.700 | Flush |
| 2nd | 014-20 | Fountain Adj to Girls Rm | 2/7/18 | 7:24 | 0.007 | 0.294 | Plastic Pipe |
| 2nd | 014-21 | Fountain Adj to Boys Rm | 2/7/18 | 7:25 | 0.007 | 0.951 | Plastic Pipe |